

The following is a list of buildings on campus with the Areas of Rescue Assistance:

AC - Panel at North entrance, 3 remotes in Southwest stairwell--Floors 1-3

BH - Panel in Chester Ave vestibule, 10 remotes in North, Center, South Stairwells --Floors Lower Pk-4

EC2 - Panel in lobby on West wall, 6 remotes in Stairwells A, B--Floors 2-4

EC3 - Panel at side entrance on West wall, 6 remotes in North & South stairwells --Floors 2-4

EC4 - Panel in Main Lobby next to Fire Alarm panel, 11 remotes in Stairwells A, B--Floors 1-4

FT - Panel in locked closet in lobby hallway, 3 remotes in Center stairwell--Floors 5-7

JH - Panel in Euclid Ave vestibule, 2 remotes in Northwest stairwell--Floors 2-3

LB - Panel in Euclid Ave vestibule, 2 remotes in South stairwell--Floors 1-2

MB - No Panel, 16 remotes located in North, West, and South Stairwells, Floors 2-5

MM - Panel in lobby office, 3 remotes in North stairwell --in Basement & Floors 2-3

PH - Panel at East entrance, 3 remotes in South stairwell--in Basement & Floors 2-3

PE - Panel at West entrance, 4 remotes in East & West stairwells--Floors 2-3

PS - Panel in Main Lobby, 4 remotes in East stairwell--Floors 2-5

RC - Panel at Day Care entrance, 9 remotes in Stairwells A, E, F --from Garage to Roof

RT - Panel in Fire Alarm Control Room ground level, 24 remotes in multiple locations throughout

SI - Panel located in Main Lobby, 5 remotes in Southeast stairwells, --from Lower Park-4th Floor

SR - Panel located in Lower Lobby, 6 remotes in East, Center, West stairwells--Floors 2-4

SC - Panel located in Euclid Ave vestibule, 2 remotes in Northwest stairwell--Floors 2-3

WH - Panel located at East entrance next to remote annunciator, 4 remote stairwell locations Floors 3 & 4 East and West

Wherever there is a panel, there is two (2)-way communication between the stairwell remote and the panel itself. CSU PD dispatch is immediately notified when one of locations is activated and it tells the dispatcher the exact location that has been activated so that someone can be dispatched to respond and investigate.

#### Exceptions:

Middough Building where only a recorded message is sent to dispatch identifying the location.

Law Building sends a signal to dispatch but has no voice communication between the remote location and the panel.